



Tahoe City Public Utility District 2017 Madden Creek Water System - Annual Water Quality Consumer Confidence Report

**Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien**

To Our Valued Madden Creek Customers:

The enclosed information is a report of the quality and laboratory analysis of the drinking water that was delivered to the Madden Creek Water System during the calendar year of 2017 by the previous owner, Mid-Sierra Utilities. As you may know, TCPUD took ownership of the Madden Creek Water System on January 2, 2018. While TCPUD did not collect water quality samples in 2017, and while we were not responsible for system water quality in 2017, we are using all available public records to provide you this important information for the 2017 calendar year. On page two you will find a table showing data from samples collected by Mid-Sierra and contains all detected contaminants in the water, as well as general information on water quality and different standard health effect language for various contaminants.

While water supplied to Madden Creek is groundwater which comes from a well drilled deep within the earth, it is important for you to understand all potential sources of drinking water. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants such as viruses and bacteria that may come from sewage treatment plants, septic systems and wildlife.
- Inorganic contaminants such as salts and metals that can be naturally occurring or result urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and Herbicides which may come from a variety of sources such as storm water runoff and residential uses.
- Organic chemical contaminants including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (U.S. EPA) and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

For questions or additional information please call Utilities Superintendent, Dan Lewis, at (530) 580-6330 or the USEPA Safe Drinking Water Hotline at (800) 426-4791 or their website: <https://www.epa.gov/ground-water-and-drinking-water> For general district information, expressing your views, or participating in the decision making process of the TCPUD you are welcome to attend any or all of our Board of Directors meetings. The District Board of Directors meeting schedule and agendas are available on our website www.tcpud.org or contact the District Clerk's office at (530) 580-6052.

Detected Compounds

The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. If a substance or contaminant is not listed, it is either not detected above the detection limit in our sources or not required to be reported or sampled.


Identify your system >				Madden Creek	Violation	Major Origins in Drinking Water
Contaminant (Units)	Sample Year	MCL	PHG (MCLG)	Silver Street Well		
Primary Drinking Water Standards (PDWS)						
Cyanide (ppb)	2006	150	150	8.1		Discharge from steel/metal, plastic and fertilizer factories
Lead (ppb)		15	0.2			Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Secondary Drinking Water Standards (SDWS)						
Chloride (ppm)	2006	500		1.2	N/A	Leaching from natural deposits
Iron (ppb)	2006	300		75		Leaching from natural deposits; industrial wastes
Sodium (ppm)	2006	N/R	N/R	3.9	N/A	Leaching from natural deposits
Total Dissolved Solids (ppm)	2006	1000	N/A	90	NO	Erosion of natural deposits
Total Hardness [as CaCO ₃] (ppm)	2006	N/A	N/A	42	N/A	Leaching from natural deposits
Turbidity (NTU)						Movement of sediments and minute deposits
Microbiological Monitoring						
Total Coliform (P/A)	2017	1	(0)	10T/10 A/ 0P	Yes (B)	Naturally present in the environment
E-Coli (P/A)	2017	1	(0)	10T/10 A/ 0P	NO	Human and Animal Fecal Waste

Lead and Copper Sampling Results							
Water System	Constituent	Year Sampled	# of Sites Sampled	90th % Results	# of Sites Exceeding Action Level	Action Level	PHG
Madden Creek	Lead (ppb)	2014	5	10	0	15	0.2
	Copper (ppm)		5	0.045	0	1.3	0.3
Zero schools requested Lead and Copper sampling in 2017							
Typical Sources:	Lead: Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits						
	Copper: Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives						

Water Conservation Links:

www.saveourh2o.org -or- www.saveourwater.com/
www.h2ouse.org/
www.epa.gov/watersense/
www.wateruseitwisely.com/100-ways-to-serve/index.php
www.tahoercd.org/ Landscaping for Conservation
www.cuwcc.org/ California Urban Water Council
www.waterboards.ca.gov/waterrights/water_issues/programs/drought/

B. Note on Total Coliform Violation: The Madden Creek Water Company failed to monitor as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Enclosed is the notice you should have received in 2017 which explained the situation in detail.



Tahoe City Public Utility District
P. O. Box 5249
Tahoe City, CA 96145
www.tcpud.org
530-583-3796



Terms and Abbreviations Used in This Report

A	Number of tests absent of bacteria	PDWS	Primary Drinking Water Standards. MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.	PHG	Public Health Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.	PPB	Parts Per Billion: Parts contaminant for every 1 billion parts of water.
N/A	Not Applicable	PPM	Parts Per Million: Parts contaminant for every 1 million parts of water.
N/R	Not Regulated or Not Required	SDWS	Secondary Drinking Water Standards. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
NTU	Nephelometric Turbidity Unit: Measure of water clarity using light scattering	T	Number of tests for bacteria (Laboratory analysis)
P	Number of tests detecting presence of bacteria	Units	Number of units measured

Health Effects and General Information

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and your children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. TCPUD is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Where does your water come from?

All of the drinking water supplied to each water system is classified as groundwater. Sources include wells and springs drilled deep into the ground, providing clean, high quality water that consistently meets all standards without significant treatment. The Madden creek Water System serves all residents from Cherry Street to Tahoe Ski Bowl Way in Homewood, CA. There have been no contaminants detected in the water supply, however the sources are still considered vulnerable to the activities located near the drinking water source. Well construction and security measures should provide protection from most contaminating activities. Copies of all source water assessments are available for review at the TCPUD offices during regular business hours. Upon request, copies can be sent to individuals by contacting the Utilities Superintendent at (530) 580-6330.

**Este informe contiene información importante sobre su agua potable.
Traduzcalo o hable con alguien que lo entienda bien.**

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

**Monitoring Requirements Not Met for
Madden Creek Water Company**

The previous water company failed to monitor as required for drinking water standards during 2017 and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as customers, you have a right to know what you should do, what happened, and what was done to correct this situation.

The previous water company was required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During February 2017 the previous water company failed to perform the required monthly monitoring for total coliform bacteria, and therefore, could not be sure of the quality of our drinking water during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) that the previous water company did not properly test-for during the last year, how many samples we are required to take and how often, how many samples were collected, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

<i>Contaminant</i>	<i>Required Sampling Frequency</i>	<i>Number of Samples Taken</i>	<i>When All Samples Should Have Been Taken</i>	<i>When Samples Were or Will Be Taken</i>
Total Coliform Bacteria	One sample per month	0	February 2017	March 2017

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

The previous water company performed the required monthly monitoring for total coliform bacteria during March and April 2017, and no total coliform bacteria was detected in the water system.

For more information, please contact the Utilities Superintendent, Dan Lewis, at 530-580-6330.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing

homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(9)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you on behalf of the previous water company (State Water System # 3110043)